


Facade line/position to follow the information supplied by FK this follows the grid line as either 358 or 278mm offset and the door cill profile 233mm off gridline. (see drawing for further details)




Indicative waterproofing as per FK

Walk on cill detail by others

2 Detail view
Scale 1:4

Building
3mm angle tack welded into I beam not waterproof. To finish flush with side of I beam.

158x152x30 Galvanised stub brackets




3 Plan View

Waterproof by others
Farrat Thermal Break
Indicative Fire break (Position TBA by others)
Gusset welded into web of arm to assist waterproofer in waterproofing the balcony arms (Web infill not waterproof seal).

1 Section Through

On level 1 in locations shown on GA plan, some balconies have extra water collection tray- refer to details on M001-SAP-ZZ-DR-X20-220



Aluminium Profiled Capping
Satin Anodized Finish

10+10mm THK laminated
clear toughened and
heatsoaked glass panels

Sapphire composite decking.
Sapphire Brown P6 Sample
provided and AHR approved.

Screen printed glass
RAL 9003.

60 diameter discs on
the front of the glass

Top of screen printed band

M30x80 Galvanised bolt

M16x80 M16 Galvanised bolt

Inside FFL

Anti slid
off plate.

Aluminium balcony
cassette

Aluminium soffit trays
PPC RAL 9003

158x152x30 Galvanised stub
brackets

158x152x30 UC
galvanized support arm

Soffit to stop 20mm away
from rainscreen

Aluminium rainscreen
panel (By others)

C5	19.05.18	Issued For Construction
C4	29.11.17	As per markup
C3	20.11.17	Updated to arch Comments - For approval

Rev	Date	Description
Project Media City		

Location
Tower Block

Drawing Title
Typical Balcony Section



www.sapphirebalustrades.com
call 0844 88 00 553

Drawn by ARD Checked by EL Scale @ A3 1:10

Media City drawing reference number
M001-SAP-XX-ZZ-DR-X-20-201

Sapphire Ref.
529930 SE-01 C5